


Truss ReinforcementBL-37 Truss Reinforcement



DRAWINGS FOR ILLUSTRATIVE PURPOSES ONLY

Material Conformances - Joint Reinforcement Blok-Lok joint reinforcement products conform to ASTM A951/A951M (Standard Specification for Steel Wire for Masonry Joint Reinforcement) ACI / ASCE 530 (Building Code Requirements for Masonry Structures) CSA standard A370-14.
Wire: (Carbon Steel): Prefabricated construction from cold-drawn steel wire conforming to ASTM A 82: Tensile Strength - 80,000 p.s.i. Yield Point - 70,000 p.s.i. minimum
AND THE STATE OF T

Wire Diameter:

9 gauge (.148" or W1.7) 3/16" (.187" or W2.8)

Side Rods and Cross Rods available in any combination of the above. Cross Rods welded 16" O.C.

First Cross Rods welded 12" in from each end to allow lap splices per code requirements.

Note: Bed joint alignment for connecting wythes recommended.

Blok-Lok manufactures steel wire products from a minimum of 95% recycled material.

Finis	snes:	
	Hot-Dip Galvanized after fabrication: ASTM A 153 (1.5 oz/ft²)	
	Stainless Steel: ASTM A 580 - AISI Type 304 (Type 316 available on special order).	
Note	: Blok-Lok recommends Stainless Steel for maximum protection against corrosion.	
Wire Size:		

Wire Size:		
	Standard: 9 Gauge Side Rods x 9 Gauge Cross Rods	
	Heavy Duty: 3/16" Side Rods x 9 Gauge Cross Rods	
	Extra Heavy Duty: 3/16" Side Rods x 3/16" Cross Rods	
Block Size:		
	4"	

Note: State overall wall thickness when ordering.

12 Ashbridge Circle | Woodbridge, Ontario, L4L 3R5, Canada

T: 905.266.2277 | F: 905.266.2272 | USA: 1.800.561.3026

sales@blok-lok.com | www.blok-lok.com

10"